

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-1275038
Name of Facility: International Studies Preparatory Academy
Address: 1570 Madruga Avenue
City, Zip: Miami 33146

Type: Public Schools
Owner: Miami-Dade County School Board
Person In Charge: Felicia Diaz Phone: 305 663-7200
PIC Email: feliciadiaz@dadeschools.net

**Correct By: Next Inspection
Re-Inspection Date: None**

Inspection Information

Purpose: Routine
Inspection Date: 3/15/2019

Begin Time: 04:05 PM
End Time: 05:05 PM

Additional Information

FEMALES 242
MALES 118

CENSUS 360

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION			
<u>IN</u> 1. School Site	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control	
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 12. Toilet Facilities	SAFETY	
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit	
BUILDING CONST/MAINT.	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION	
<u>IN</u> 4. Construction	<u>IN</u> 15. Shower Facilities	<u>IN</u> 23. Sanitizers	
<u>IN</u> 5. Maintenance & Repair	<u>IN</u> 16. Showers Water Temperatures	<u>IN</u> 24. Changing Station & Mats	
<u>IN</u> 6. Lighting Standards	WATER SUPPLY	<u>IN</u> 25. Hand Sink	
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 17. Approved Source	<u>IN</u> 26. Garbage Can	
<u>IN</u> 8. Natural Ventilation	<u>OUT</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY	
<u>IN</u> 9. Mechanical Ventilation	LIQUID WASTE & WASTE WATER	<u>IN</u> 27. Animal Maintenance/Aggressive	
SANITARY FACILITIES	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES	
<u>IN</u> 10. Provided/Accessible/Separation	<u>IN</u> 20. Solid Waste	<u>IN</u> 28. Maintenance/Complaint	
	PEST CONTROL	<u>IN</u> 29. Other	

Marking Key: *IN* = the act or item was observed to meet standards; *OUT* = the act or item was observed not to meet standards; *NO* = the act or item was not observed to be occurring at the time of inspection; *NA* = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

No General Comments Available

Email Address(es): feliciadiaz@dadeschools.net;
ipalacio@dadeschools.net;
jware@dadeschools.net;
jaybolton@dadeschools.net

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #18. Drinking Fountains
Increase water pressure for all water fountains throughout the school.
CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Manuel Alzugaray (27431)
Inspector Contact Number: Work: (786) 216-9760 ex.
Print Client Name:
Date: 3/15/2019

Inspector Signature:

Handwritten signature of Manuel Alzugaray.

Client Signature:

Handwritten signature of the client.