



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

**Violation #3. Athletic & Playground Equipment**

Observed missing rubber patting around cast iron weighted plates. Repair/replace cast iron weighted plates.

CODE REFERENCE: 3. Athletic and Playground Equipment. 5(2)(k)4 SREF. Athletic and playground equipment, where provided, shall be structurally sound, maintained firm and stable, vermin-proof, free of pockets or crevices where water will collect or vermin and pests may hide, and free from jagged or sharp projections, edges, or corners. Playground equipment includes the equipment itself (backstops, swings, slides, etc.) and its structural components (foundations, supporting members, exposed fasteners, etc.).

**Violation #6. Lighting Standards**

Observed dimmed lights (38.5fc) of testing center of 5th floor. Replace light bulbs.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

**Violation #13. Handwashing Facilities**

Observed loose faucets in bathroom #417 and #318. Secure faucets.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Javon Johnakin (27326)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name:  
Date: 8/15/2023

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.